



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: MAI H/S

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 08/30/2016 12:40
Reported: 09/20/2016 22:15

Analytical Testing Parameters

Client Sample ID: 33-1
Lab Sample ID: J610250-01
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/29/16
Collection Time: 08:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		09/09/16 1607	09/12/16 1152

Analytical Testing Parameters

Client Sample ID: 33-2
Lab Sample ID: J610250-02
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/29/16
Collection Time: 08:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		09/09/16 1607	09/12/16 1154

Analytical Testing Parameters

Client Sample ID: 26-1
Lab Sample ID: J610250-03
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/29/16
Collection Time: 08:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		09/09/16 1607	09/12/16 1155



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 26-2
Lab Sample ID: J6I0250-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/29/16
Collection Time: 08:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1157

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J6I0250-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0022, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1158

Analytical Testing Parameters

Client Sample ID: 2-2
Lab Sample ID: J6I0250-06
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1206



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 38-1
Lab Sample ID: J6I0250-07
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 09:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1207.

Analytical Testing Parameters

Client Sample ID: 38-2
Lab Sample ID: J6I0250-08
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 09:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1209.

Analytical Testing Parameters

Client Sample ID: 23-1
Lab Sample ID: J6I0250-09
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0014, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1210.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 23-2
Lab Sample ID: J6I0250-10
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1212.

Analytical Testing Parameters

Client Sample ID: 24-1
Lab Sample ID: J6I0250-11
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0014, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1213.

Analytical Testing Parameters

Client Sample ID: 24-2
Lab Sample ID: J6I0250-12
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1215.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6I0250-13
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1216

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6I0250-14
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1217

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6I0250-15
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1219



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6I0250-16
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1226

Analytical Testing Parameters

Client Sample ID: 35-1
Lab Sample ID: J6I0250-17
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0015, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1228

Analytical Testing Parameters

Client Sample ID: 35-2
Lab Sample ID: J6I0250-18
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1229



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 32-1
Lab Sample ID: J6I0250-19
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0040, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1231

Analytical Testing Parameters

Client Sample ID: 32-2
Lab Sample ID: J6I0250-20
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1232

Analytical Testing Parameters

Client Sample ID: 37-1
Lab Sample ID: J6I0250-21
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1234



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 37-2
Lab Sample ID: J610250-22
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1235

Analytical Testing Parameters

Client Sample ID: 34-1
Lab Sample ID: J610250-23
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0014, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1237

Analytical Testing Parameters

Client Sample ID: 34-2
Lab Sample ID: J610250-24
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1241



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 41-1
Lab Sample ID: J6I0250-25
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1243

Analytical Testing Parameters

Client Sample ID: 41-2
Lab Sample ID: J6I0250-26
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1247

Analytical Testing Parameters

Client Sample ID: 27-1
Lab Sample ID: J6I0250-27
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0032, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1248



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 27-2
Lab Sample ID: J610250-28
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1250

Analytical Testing Parameters

Client Sample ID: 36-1
Lab Sample ID: J610250-29
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1251

Analytical Testing Parameters

Client Sample ID: 36-2
Lab Sample ID: J610250-30
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1253



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J6I0250-31
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0059, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1254

Analytical Testing Parameters

Client Sample ID: 3-2
Lab Sample ID: J6I0250-32
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0011, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1259

Analytical Testing Parameters

Client Sample ID: 31-1
Lab Sample ID: J6I0250-33
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1300



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 31-2
Lab Sample ID: J6I0250-34
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1302

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J6I0250-35
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0073, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1303

Analytical Testing Parameters

Client Sample ID: 1-2
Lab Sample ID: J6I0250-36
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1307



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 10-1
Lab Sample ID: J610250-37
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/09/16 1607, 09/12/16 1309.

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J610250-38
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1325.

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J610250-39
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0016, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1329.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6I0250-40
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1331

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6I0250-41
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1332

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6I0250-42
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1334



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J610250-43
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1335

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J610250-44
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1337

Analytical Testing Parameters

Client Sample ID: 25-1
Lab Sample ID: J610250-45
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1338



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 25-2
Lab Sample ID: J610250-46
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1343

Analytical Testing Parameters

Client Sample ID: 13-1
Lab Sample ID: J610250-47
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.015, 0.015, 0.0010, mg/L, G, 09/13/16 0925, 09/13/16 1344

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J610250-48
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1346



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J610250-49
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0014, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1347

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J610250-50
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1348

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J610250-51
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: N/A

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0014, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1353



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J610250-52
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1354

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J610250-53
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0049, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1356

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J610250-54
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1400



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 40-1
Lab Sample ID: J610250-55
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 09:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0016, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1402

Analytical Testing Parameters

Client Sample ID: 40-2
Lab Sample ID: J610250-56
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 09:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0016, 0.015, 0.0010, mg/L, 09/13/16 0925, 09/13/16 1403

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J610250-57
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1542



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6I0250-58
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1544

Analytical Testing Parameters

Client Sample ID: 34-1
Lab Sample ID: J6I0250-59
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0074, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1545

Analytical Testing Parameters

Client Sample ID: 34-2
Lab Sample ID: J6I0250-60
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1546



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 22-1
Lab Sample ID: J6I0250-61
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0019, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1551

Analytical Testing Parameters

Client Sample ID: 22-2
Lab Sample ID: J6I0250-62
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1552

Analytical Testing Parameters

Client Sample ID: 39-1
Lab Sample ID: J6I0250-63
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0074, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1554



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610250

Analytical Testing Parameters

Client Sample ID: 39-2
Lab Sample ID: J610250-64
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 09:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0031, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1555

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J610250-65
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1600

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J610250-66
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1601



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 29-1
Lab Sample ID: J6I0250-67
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1603.

Analytical Testing Parameters

Client Sample ID: 29-2
Lab Sample ID: J6I0250-68
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1604.

Analytical Testing Parameters

Client Sample ID: 9-ICE
Lab Sample ID: J6I0250-69RE1
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0034, 0.015, 0.0010, mg/L, 09/14/16 1424, 09/16/16 1650.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 30-ICE
Lab Sample ID: J6I0250-70
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 09:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1606

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6I0250-71
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1610

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6I0250-72
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1612



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 28-1
Lab Sample ID: J6I0250-73
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1613

Analytical Testing Parameters

Client Sample ID: 28-2
Lab Sample ID: J6I0250-74
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1618

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6I0250-75
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1619



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0250

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6I0250-76
Sample Type: Grab

Collected By: RF-Client
Collection Date: 08/25/16
Collection Time: 08:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 09/14/16 1523, 09/15/16 1621

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Items include Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required).

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863
New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
09/20/2016 22:15

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

MAL #15

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES			Ice:	YES NO		
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO		
Contact:	Ray Filley			Sample Temp:			
Phone:	315-779-7054			Cooler Seal:	YES NO		
Project:	Lead Testing			Pickup:	YES NO		
Quote ID:		PO#:		Dropoff:	C W		
Ruth TAT Bur. Days:	2-5 5-7 7-10	Date Req:		Accepted?	YES NO		
Release to DOH:	Yes			Container Material:			
Email Results:	Yes	Email:	rfilley@boces.com / rfilley@boces.com	Container size(in MI)			
Fax Results:	Yes			Preservative:			
Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type			
1 33-1	8/29	8:35	RF				
2 33-2		8:36					
3 26-1		8:26					
4 26-2		8:27					
5							
6							
7							
8							

Sampled:	Print Name and Company	Signature	Date/Time
Received:	RAY FILLEY	<i>[Signature]</i>	8/30/2000
Received:	Ray Filley	<i>[Signature]</i>	8/30/2000
Received:	Catherine P. Hurst	<i>[Signature]</i>	8/30/2000
Received:			
Received:			



J610250

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)763-3403 Fax:(607)763-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

MAA #/S

MNY Workorder #

Client Information				Billing/Invoice:			
Name: Jefferson-Lewis-Hamilton-Herkimer-Onida BOCES				Analysis Requested			
Address: 20104 NYS Route 3				Ice: YES NO			
Watertown, NY 13601				Cooler: YES NO			
Contact: Ray Filley				Sample Temp: YES NO			
Phone: 315-779-7054				Cooler Seal: YES NO			
Project: Lead Testing				Pickup: YES NO			
Quote ID: PO#:				Dropoff: C W			
Rush TAT Bus. Days: < 2-5 5-7 7-10 Date Req.:				Accepted? YES NO			
Release to DOH: Yes				Container Material			
Email Results: Yes				Container Size(in MI)			
Fax Results: Yes				Preservative			
Email: filley@boes.com / fhauck@boes.com				Comments/Field Data			
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 2-1	8/25	7:58	RF				
2 2-2		7:59					
3 38-1		9:04					
4 38-2		9:05					
5 23-1		8:41					
6 23-2		8:42					
7 24-1		8:48					
8 24-2		8:49					
Sampled: <i>Ray Filley</i>				Signature: <i>[Signature]</i>			
Received: <i>Lead Thomas</i>				Date/Time: 8/29 1030			
Received:				Date/Time: 8/30 1290			
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this testing.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10796, EPA #NY00896

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

MAY #1/S

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Onesida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bur. Days:	3 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH:	Yes					Container Material:	
Email Results:	Yes					Container Size (in MI):	
Fax Results:	Yes					Preservative:	
						Comments/Field Data:	

Sample Information		Matrix		Number of Containers for Analysis Requested		Date/Time	Comments
Description/Location	Date	Time	Initial	Type			
20-1	8/25	8:18	RF				
20-2		8:19					
19-1		8:23					
19-2		8:24					
55-1		8:28					
35-2		8:29					
32-1		8:38					
32-2		8:39					

Sampled:	Ray Filley	Signature:	Ray Filley	Date/Time:	8/29 1030
Received:	Ray Filley	Signature:	Ray Filley	Date/Time:	8/30 1240
Received:		Signature:		Date/Time:	
Received:		Signature:		Date/Time:	
Received:		Signature:		Date/Time:	
Received:		Signature:		Date/Time:	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the terms and conditions of the subcontract.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)			
Name: Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: Rush TAT Bus. Days: 2-5 5-7 7-10 Release to DOH: Yes Email Results: Yes Fax Results: Yes				PO#: Date Req.: Email: rfilley@boCES.com Fax: rfilley@boCES.com				Analytically Requested Number of Containers for Analysis Requested Comments/Field Data				Ice: YES NO Cooler: YES NO Sample Temp: Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container size(in MI) Preservative			
Sample Information				Matrix				Comments							
Description/Location	Date	Time	Initial	Type	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data	Date/Time	Signature	Comments				
1 37-1	8/5	8:57	RF		250	HINO3			8/19/2008						
2 37-2		8:58													
3 34-1		8:32													
4 34-2		8:33													
5 41-1		8:54													
6 41-2		8:55													
7 27-1		8:40													
8 27-2		8:41							8/30/2008						
Sampled: Ray Filley				Signature:											
Received:				Signature:											
Received:				Signature:											
Received:				Signature:											
Received:				Signature:											
Received:				Signature:											

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with it.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MAX 4/3

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oswego ROCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	filley@boces.com / rfilley@boces.com					Container size(in MI)	
Fax Results: Yes						Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 36-1	8/25	8:30	RF				
2 36-2		8:31					
3 3-1		8:00					
4 3-2		8:01					
5 31-1		7:24					
6 31-2		7:25					
7 1-1		7:57					
8 1-2		7:58					
Print Name and Company		Signature		Date/Time			
Sampled: Ray Filley							
Received: Ray Filley							
Received: Ray Filley							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the subcontract.

3821 Buck Drive
 Cortland NY 13046
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10796, EPA #NY009936

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

MAX HB

MNY Workorder #

Client Information				Billing/Invoice:				Analysis Requested				Receiving Info (Lab Use Only)													
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		Address: 20104 NYS Route 3 Watertown, NY 13601		Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing		Quote ID: PO#:		Ruth TAT Bur. Days: <1 2-5 5-7 7-10 Release to DOH: Yes		Email Results: Yes Fax Results: Yes		Ice: YES NO		Cooler: YES NO		Sample Temp: YES NO		Cooler Seal: YES NO		Pickup: YES NO		Dropoff: C W		Accepted? YES NO	
Sample Information				Matrix Type				Number of Containers for Analysis Requested				Comments/Field Data													
Description/Location	Date	Time	Initial	Matrix	Type																				
1 10-1	8/25	7:52	RF																						
2 10-2		7:53																							
3 7-1		8:07																							
4 7-2		8:08																							
5 17-1		7:39																							
6 17-2		7:40																							
7 14-1		7:35																							
8 14-2		7:36																							
Sampled: Ray Filley				Signature: <i>Ray Filley</i>				Date/Time: 8/29 2000				Comments:													
Received: David James				Signature: <i>David James</i>				Date/Time: 8/30 12:40				Comments:													
Received:				Signature:				Date/Time:				Comments:													
Received:				Signature:				Date/Time:				Comments:													
Received:				Signature:				Date/Time:				Comments:													
Received:				Signature:				Date/Time:				Comments:													

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the subcontract.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MAI 4/5

MNY Workorder #

Client Information		Billing/Invoice:		Analytix Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		20104 NYS Route 3				Ice: YES NO	
Address: Watertown, NY 13601		Ray Filley				Cooler: YES NO	
Contact: 315-779-7054		Lead Testing				Sample Temp: YES NO	
Project: PO#:		Date Req:				Cooler Seal: YES NO	
Rush TAT Bus. Days: 2-5 5-7 7-10		Email Results: Yes		2008 Lead		Pickup: YES NO	
Relocate to DOH: Yes		Fax Results: Yes		P		Dropoff: C W	
Email Results: Yes		250				Accepted? YES NO	
Fax Results: Yes		HNO3				Container Material	
Email Results: Yes		f.filley@boces.com / fhack@boces.com				Container size (in MI)	
Sample Information		Number of Containers for Analysis Requested				Preservative	
Description/Location	Date	Time	Initial	Matrix Type	Comments/Field Data		
1 22-1	8/15	8:45	RF				
2 22-2	8/16	8:46					
3 39-1	8/19	8:59					
4 39-2	9/00	9:00					
5 4-1	8/02	8:02					
6 4-2	8/03	8:03					
7 29-1	7/22	7:22					
8 29-2	7/23	7:23					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Ray Filley				8/19 2008			
Received: David Thomas				8/30 12:50			
Received:							
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with that.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MAL 4/5

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: _____ Rush TAT Bus. Days: 2-5 5-7 7-10 Release to DOH: Yes Email Results: Yes Fax Results: Yes		PO#: _____ Date Req: _____ Email: rfilley@boces.com / fhauck@boces.com		Analysis Requested 		Ice: YES NO Cooler: YES NO Sample Temp: _____ Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
1 9-1CE	8/25	8:15	RF				
2 30-1CE		9:07					
3 21-1		8:44					
4 21-2		8:45					
5 28-1		7:21					
6 28-2		7:22					
7 18-1		8:20					
8 18-2		8:21					
Sampled: Ray Filley Received: Andrew James Received: Received: Received:				Date/Time 8/29 10:00 8/30 12:30			
Print Name and Company Signature: <i>Ray Filley</i> <i>Andrew James</i>				Comments			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.